

Bureau Veritas

Fire Plan Review Submittal Requirements

Minimum Fire Sprinkler, Fire Alarm and Fire Suppression Hood System submittal requirements.

_____ Complete Fire Permit Application (with contact information & Email address)

Fire Sprinkler Submittal Requirements

Comply with NFPA 13, 13R or 13D

_____ Plans with stamp and signature of designer

_____ Cut Sheets

_____ Hydraulic Calculations

_____ Hydrant Flow Data performed within 6 months of design of system

Fire Alarm Submittal Requirements

Comply with NFPA 72

_____ Plans with stamp and signature of designer

_____ Cut Sheets

_____ Battery Calculations

Fire Hood Suppression Systems

_____ Plans with stamp and signature of designer

_____ Cut Sheets

Submit a minimum of 4 sets of plans

_____ 3 sets to be sent to Bureau Veritas

_____ 1 set for the City